



R W Building Consultants, Inc.

Consulting and Engineering Services for the Building Industry

P.O. Box 230 Valrico, FL 33595 Phone 813.659.9197 Facsimile 813.754.9989

Florida Board of Professional Engineers Certificate of Authorization No. 9813

Product Evaluation Report

Report No.: FL 6229.9 R1
Date: September 30, 2008
Product Category: Exterior Doors
Product sub-category: Swinging Exterior Door Assemblies
Product Name: Distinction Series Glazed Fiberglass Doors
Full and ¾ Lite Inswing / Outswing
"Non-Impact"
Manufacturer: Nan Ya Plastics Corporation
Plastpro Inc.
9 Peach Tree Hill Road
Livingston, NJ 07039
Phone: 800-779-0561 Facsimile: 973-758-4001

Scope: This is a Product Evaluation report issued by R W Building Consultants, Inc. and Lyndon F. Schmidt, P.E. (System ID # 1998) for Nan Ya Plastics Corporation, Plastpro Inc. based on Rule Chapter No. 9B-72.070, Method 1d of the State of Florida Product Approval, Department of Community Affairs-Florida Building Commission.

RW Building Consultants and Lyndon F. Schmidt, P.E. do not have nor will acquire financial interest in the company manufacturing or distributing the product or in any other entity involved in the approval process of the product named herein.

This product has been evaluated for use in locations adhering to the Florida Building Code (2007 Edition).

See Drawing No. FL-6229.9 prepared by R W Building Consultants, Inc. and signed and sealed by Lyndon F. Schmidt, P.E. (FL # 43409) for specific use parameters.

Lyndon F. Schmidt, P.E.
FL No. 43409
September 30, 2008

Limitations

1. This product has been evaluated and is in compliance with the 2007 Florida Building Code (FBC) structural requirements excluding the "High Velocity Hurricane Zone" (HVHZ).
2. Product anchors shall be as listed and spaced as shown on details. Anchor embedment to base material shall be beyond wall dressing or stucco.
3. When used in areas requiring wind borne debris protection this product is required to be protected with an impact resistant covering that complies with Section 1609.1.2 of the 2007 FBC.
4. For 2x stud framing construction, anchoring of these units shall be the same as that shown for 2x buck masonry construction.
5. Site conditions that deviate from the details of this drawing require further engineering analysis by a licensed engineer or registered architect.
6. See drawing FL-6229.9 for size and design pressure limitations.



Lyndon F. Schmidt, P.E.
FL No. 43409
September 30, 2008

Supporting Documents

- A Drawing
1. Drawing No. FL-6229.9 prepared by R W Building Consultants, Inc. (Florida Board of Professional Engineers Certificate of Authorization No. 9813), signed and sealed by Lyndon F. Schmidt, P.E.
- B Tests Performed
1. Testing per 101/I.S.2-97 as performed by Certified Testing Laboratories and reported in test report number CTLA 900 W5-13, signed and sealed by Ramesh Patel, P.E.
- C Calculations
1. Product anchoring is in accordance with manufacturer's published recommendations as substantiated by tested specimens reported in test report numbers CTLA 900 W5-13.
 2. Buck anchor analysis for loading conditions, prepared, signed and sealed by Lyndon F. Schmidt, P.E.
- D Other
1. Certificate of Participation issued by National Accreditation & Management Institute, Inc., certifying that Nan Ya Plastics Corporation, Plastpro Inc is manufacturing products within a quality assurance program that complies with ISO/IEC 17020 and Guide 53.



Lyndon F. Schmidt, P.E.
FL No. 43409
September 30, 2008